



Product Overview

The EtherNet/IP Scanner interface can only be mounted in the top slot of the Anybus X-gateway.

Top view



Front view




LED Indicators

LED	Indication	Meaning
GW Status		See Gateway Installation Sheet
LA	Green	Link established
	Green (flashing)	Receiving/transmitting data
	Off	Link not detected
MS	Green	Normal operation
	Green (flashing)	Standby, not yet configured
	Red	Major fault, unrecoverable
	Red (flashing)	Minor fault, recoverable
	Red/green (alternating)	Hardware self test
	Off	No power
	NS	Green
Green (flashing)		No EtherNet/IP connections
Red		Duplicate IP address
Red (flashing)		Connection timeout
Red/green (alternating)		Hardware self test
Off		No power or no IP address set

IP Address Configuration Switches

Sets the binary value of the last byte of the IP address within subnet 192.168.0.1–254 (netmask 255.255.255.0). To use a different subnet, set all switches to **OFF** and configure with Anybus IPconfig.

128	64	32	16	8	4	2	1	Binary value
OFF	IP address set with IPconfig							
OFF	ON	192.168.0.1						
OFF	OFF	OFF	OFF	OFF	OFF	ON	OFF	192.168.0.2
ON	OFF	192.168.0.254						
ON	(Not valid)							
1	2	3	4	5	6	7	8	Switch number



Accessories Checklist

The following items are required for installation:

- EtherNet/IP configuration tool (optional, not included)
- USB cable (included)
- EDS file for EtherNet/IP (see www.anybus.com)
- LAN cable (not included)

Installation and Startup Summary

(Depending on your setup, some steps may not be required.)


1. Connect the gateway to the EtherNet/IP network
2. Set a valid IP address for the EtherNet/IP interface (contact your network administrator for information)
3. Connect a PC to the gateway via USB
4. Power up and configure the gateway
5. Install the EDS file in the EtherNet/IP configuration tool

Technical Support

Technical support, documentation and software downloads are available at www.anybus.com.

Technical questions regarding the EtherNet/IP fieldbus system should be addressed to **ODVA** at www.odva.org.

EtherNet/IP (RJ45) Connector



Pin	Signal
1	TD+
2	TD-
3	RD+
4, 5, 7, 8	Termination to PE
6	RD-